

Kamco

CLEARFLOW CF40 EVOLUTION & CLEARFLOW CF90 QUANTUM OPERATING + SERVICING GUIDELINES



Kamco

CF40 EVOLUTION & CF90 QUANTUM OPERATING + SERVICING GUIDELINES

SECTION A – INTRODUCTION

TECHNICAL DATA

	'CF40 Evolution'	'CF90 Quantum'
Pump Type:	Positive drive centrifugal	Positive drive centrifugal
Motor:	0.50 HP, 220v (#) or 110v	0.75 HP, 220v (#) or 110v
Degree of protection:	IP54	IP54
Motor rating:	Continuous	Continuous
Temperature range:	0°C to 75°C	0°C to 75°C
Dimensions:	W 390mm, D 440mm, H 690mm.	W 390mm, D 590mm, H 890mm
Tank capacity (to filler cap)	39 litres	57 litres
Weight (without hoses):	17kg	23kg

- # The 220v models may be used on a domestic 13 ampere supply. A 5amp fuse should be fitted in the plug top. A residual current circuit breaker adaptor should be used.

SAFETY PRECAUTIONS

- Precautions should be taken to ensure a safe working environment.
 Take care when lifting large or heavy items.
 Regularly check power leads for wear or damage, use with a residual circuit breaker.
 When handling chemicals wear suitable protective clothing, gloves and goggles.
 Use in a well ventilated area.
 PAT test (Portable Appliance Test) the electrics annually.

CONTENTS OF EACH CLEARFLOW FLUSHING KIT

Each kit comprises the following:

- Clearflow power flushing pump.
- Set of 2 x 5mtr flow and return hoses.
- 1 x 8mtr pump hose.
- 1 x 3mtr overflow hose.
- 1 x 8mtr water inlet hose.
- 2 x 0.5mtr circulation pump adaptor hoses.
- 10 part BSP adaptor set.
- Waterproof transit container.
- Comprehensive operating guidelines.
- Starter pack of flushing chemicals.
- 50 promotional leaflets for advertising.



Kamco

CF40 EVOLUTION & CF90 QUANTUM OPERATING + SERVICING GUIDELINES

SECTION B – USING THE CLEARFLOW PUMP FOR POWER FLUSHING

INTRODUCTION

Clearflow pumps are designed to power flush heating systems with minimal dismantling, by circulating water and flushing chemicals at high velocity, and then purging the dirty water from the system with a high flow of fresh, clean, water. Radiators may be individually flushed without removing or disconnecting them from the system.

Your pump may be used with any commercially available flushing and descaling chemical, including strong acids or alkalis.

SYSTEM INSPECTION AND PREPARATION

1. Turn on heating system in order to identify problem flow areas, cold radiators, or those with cold spots, etc. Switch off system.
2. Note how many turns are required to shut off radiator and lock shield valves so that settings may be re-instated after flushing to avoid system balancing. Use a copy of the chart provided to record the number of turns.
Open all (both sides of radiator) valves fully.
3. Set any thermostatic radiator valves to the fully open position. Remove the heads and check that the plunger pin moves freely. Check that diverter or zone valves are in the fully open position, setting manually if necessary.
4. If an anti-gravity / check valve is present, this must be by-passed or bridged to allow the flow reversing action to be used. It may be possible to disassemble the anti-gravity valve, and remove internal components.
5. Tie up the ball cock or turn off the mains water supply by another means.
6. Drain enough water from the system to empty the F&E tank. This can be drained into the Clearflow tank if it has been connected (connection details are in the next section).
7. With vented systems, it is necessary to cap off, or loop together, the expansion and cold feed pipes in order to avoid the flushing pump filling and overflowing the expansion tank.

The F&E pipes may be capped with push fit end caps, such as Speedfit, Prestek, or Hep20, or a temporary compression fitting gate valve.

Pumps with 220 volt motors are single phase, for use on a standard domestic supply. A five amp fuse should be fitted in the plug top. We recommend the use of a residual current circuit breaker plug or adapter for extra protection.

Depending on the configuration of the heating system looping the feed and expansion pipes together may enable these pipes to be flushed during the cleansing process, which can be beneficial when the cold feed pipe contains corrosion deposits.

NOTE 1: This will only be effective when the F&E pipes are not close coupled, or connected via an air separator, and may not remove deposits which have hardened over a long period of time.

NOTE 2: The looping connection may be made with any sturdy flexible tubing, such as Kamco hose, or Hep20, but should incorporate a valve in the loop to close the circuit when flushing individual radiators.

Capping or looping the F&E pipes are only temporary measures, which must be removed after the flushing process.

ENGINEER'S TIP: Don't drain water from the system to lower the water level in the F&E tank until after the flushing pump has been connected into the system.

Tie up the f & e tank ballcock or otherwise turn off the cold water feed, and return to the flushing pump. Open both the isolating valves, without switching on the electric motor. The head of water in the house means that heating system water will run down the flow and return hoses and into the tank. Let the water run until the tank is half full, and close both isolating valves.


You should now have emptied the f & e tank sufficiently to carry out the necessary valving or capping off of the cold feed.

NOTE: If there is a large amount of sludge or slime present in the f & e tank it must be cleaned manually and not drained into the system.

Kamco

CF40 EVOLUTION & CF90 QUANTUM OPERATING + SERVICING GUIDELINES

LOCATION AND CONNECTION OF THE FLUSHING PUMP



The connection point for the flushing pump may vary depending on the system to be cleaned, and the availability of suitable connection points.

However the optimum location is via the central heating circulation pump, using either the special hoses supplied to connect across the pump unions, or using the optional CP2 adaptor connected to the pump body. (see page F.2)

Generally the unit should be located in a room with a suitable drain point, and near to a convenient mains water supply, such as a bathroom or kitchen. The cold water supply for a washing machine or dish-washing machine is a convenient source when a mixer tap makes connection of a hose difficult. The normal precautions during work on any heating system should be taken, and it is prudent to place the pump on a waterproof groundsheet or drip tray.



Kamco

CF40 EVOLUTION & CF90 QUANTUM OPERATING + SERVICING GUIDELINES

1. Hose connections to the flushing pump

- 1a. Ensure that both valves are in the closed position (i.e. the valve handles are horizontal).



- 1b. The pump has two 5 metre flow and return hoses, fitted with 3/4" female brass hose connectors on either end of each hose.

One end of both flow and return hoses should be screwed onto the corresponding 3/4" brass nipples on rear of the hose support plate. The other ends of these hoses will be connected into the heating system.

- 1c. Connect the overflow hose connector to the 3/4" BSP male overflow fitting on the rear of the pump tank, and lead to a suitable drain point.
- 1d. Connect the 8mtr dump hose to the brass nipple on the reverse of the hose support plate, and lead the hose to a toilet pan or drain pipe gully leading to a foul sewer.
- 1e. Connect mains water supply hose 3/4" BSP female hose connector to the 3/4" brass nipple on the rear of the hose support plate. Fill the tank with water to 10cm above the minimum liquid level, and then close the water inlet valve.

- 1f. Plug in the pump to a suitable 13 amp supply fitted with an RCD adapter.

2. Hose connection to the system


Connect the flow and return hoses of the pump to the system at the selected point. This may be either:

- 2a. Across the 1 1/2" BSP unions left once the circulating pump has been removed. The circulating pump isolating valves should be closed to isolate the flushing pump from the system until power flushing is commenced.



A pair of 0.5 metre long adapter hoses, enabling the pump to be connected across the 1 1/2" unions, are supplied as standard. When used, these are screwed directly onto the 3/4" female brass hose adaptors of the flow and return hoses, giving a total hose length of 5.5 metres.

- 2b. Connection via the optional CP2 pump head adaptor (see page F.2). Remove the allen bolts that attach the circulation pump head to the pump body. Attach the adaptor to the pump body and the flow and return hoses to the short lead hoses.



2c. Across the "tails" of a radiator (having drained and disconnected the radiator) using appropriate 1/2" or 3/4" BSP adaptors to connect to the valves. The radiator valves should be closed to isolate the flushing pump from the system until power flushing is commenced.

This is likely to be the least effective method due to the restrictive effect that valves (particularly thermostatic) may have on the flow rate.

The above method is generally used on a combination boiler system when a CP2 adaptor is not available.

- 2d. Across the flow and return connections at the boiler, isolating the boiler itself. This is the preferred method when flushing a heating system prior to installing a new boiler, as corrosion debris may be purged from the heating system before the new boiler is attached. This is important with all modern boilers, particularly so if the new boiler incorporates a plate type heat exchanger with complex and narrow water passages.

Kamco

CF40 EVOLUTION & CF90 QUANTUM OPERATING + SERVICING GUIDELINES

INITIAL FLUSHING PROCEDURE (WATER ONLY STAGE, BEFORE ADDITION OF CHEMICALS)

Note: In the following procedure, the pump is first used to loosen and mobilise loose silt and debris, before forcibly expelling it together with the existing heavily contaminated system water. This rids the system of as much debris and sludge at an early stage, before establishing full, chemically treated circulation through the flushing pump.

By removing loose corrosion products from the system before addition of any chemical, the full effect of the chemical is available to disturb, loosen, and dissolve more stubborn accumulations of debris.



1. Leave the pump tank cap loose, or on by no more than one turn if water splashes whilst flushing / descaling (to allow gas to escape).
2. Check that both valves are closed (horizontal). Open the isolating valves between flushing pump and heating system and switch on pump immediately. Ensure that liquid level in tank remains at least 10 cm above the minimum mark, adding more water if necessary.
3. Allow the flushing pump to run for ten minutes, reversing the direction of flow regularly. If there is sludge and debris in the system, the water returning into the tank will be heavily discoloured as the high flow rate picks up looser debris.

4. Check all hoses and connections for leaks.
5. The pump has the ability to dump dirty water when the flow is in either direction.

Change the pump into dumping mode as follows, remembering that the flow reverser is constructed so that the direction in which the lever points also indicates the direction of flow.

- 5a. Operate the flow reverser lever so that the water is flowing through the heating system in the same direction as it is during normal heating operation.
- 5b. Rotate the valve on the return side through 180° so that the dump label is clearly visible.

By doing this, system water is diverted to waste down the dump hose, instead of returning back into the tank. The liquid level in the tank will immediately begin to fall.



- 5c. The mains water inlet supply (orange tap) should now be turned on and adjusted so that the volume of incoming water compensates for that being forced out of the system to waste. Continue dumping until the waste water runs relatively clear. Ensure that the water level in the tank remains at least 10 cm above the minimum mark at all times.

Note: If the mains water cannot keep up with the dump speed (i.e. the unit begins to empty) simply stop dumping until the tank fills up.

Continued on next page.

Kamco


CF40 EVOLUTION & CF90 QUANTUM OPERATING + SERVICING GUIDELINES

- Once the water remains reasonably clear, restore circulation by rotating the valve back through 180° into re-circulation mode.
- Check that the liquid level in the tank remains 10cm above the minimum mark. Add more water if necessary. Vent all radiators to ensure that there are no air pockets. Use a cloth to absorb any liquid expelled, as the system water may be discoloured and likely to stain.

- The flushing chemical may now be added. See page B.6.

Leave the pump tank cap loose, or on by no more than one turn, whilst flushing / descaling.

Position of the Clearflow valves during normal CIRCULATION through the heating system.



When flow reverser is in direction A, waste water will be expelled through valve A, with valve A in dump, and valve B in recirculation.

Kamco

CF40 EVOLUTION & CF90 QUANTUM OPERATING + SERVICING GUIDELINES

CHEMICAL FLUSHING PROCEDURE – WHICH CHEMICAL TO USE

Which chemical to use? POWERFLUSH FX2, or HYPER-FLUSH.
Both of these chemicals will remove sludge, and the FX2 will also remove scale from the heating system.

POWERFLUSH FX2



Use Powerflush FX2 when:

- ~ You consider the system to be heavily sludged, although basically sound and in reasonable condition.
- ~ There are no aluminium heat exchangers or radiators present in the system.
- ~ The system does not have elderly galvanised steel or stainless steel pipework installed during the 1960s copper shortage crisis.
- ~ You consider that there may be limescale deposits present in the boiler or system.

How much to use?

2.1/2 litres per ten radiators (or a little more if you consider the system to be heavily sludged).

Where and when to add FX2?

Into the pump tank whilst powerflushing, but not beforehand.

Temperature required?

FX2 may be used cold (necessary when changing a boiler), but works faster with a higher temperature. The very high flow rate of the pump means that during power flushing it is not necessary to work at temperatures above 50°C.

NEVER LEAVE FX2 IN A SYSTEM

HYPER-FLUSH



Use Hyper-Flush when:

- ~ The system contains aluminium radiators or heat exchangers.
- ~ You consider the system to have suffered severe internal corrosion and metal wastage.
- ~ The system has elderly galvanised steel or stainless steel pipework installed during the 1960s copper shortage crisis.

How much to use?

1 litre per ten radiators (or two litres if you consider the system to be heavily sludged).

Where and when to add HYPER-FLUSH?

Into the system 3-14 days prior to power flushing (via the F&E tank, or a SYSTEMSURE injector unit).

Directly into the pump tank whilst power flushing.

Temperature required?

HYPER-FLUSH works best at higher temperatures, and when used to pre-treat a system, it should be operated as hot as possible.

However, the very high flow rate of the pump means that during power flushing it is not necessary to work at temperatures above 50°C.

Use both HYPER-FLUSH and FX2 if you consider the system to be VERY HEAVILY SLUDGED.

Add HYPER-FLUSH on a prior visit up to 14 days before the power flush, and ask the householder to leave the system running as hot as possible.

Use FX2 as usual on the day of the power flush, adding directly into the pumps tank.

Kamco

CF40 EVOLUTION & CF90 QUANTUM OPERATING + SERVICING GUIDELINES

CHEMICAL FLUSHING PROCEDURE USING POWER FLUSH FX2



1. Switch on the Clearflow pump.
2. Whilst re-circulating water through the pump and the heating system, slowly add 2½ ltr of Powerflush FX2 to the tank (sufficient for 10-12 radiator system), and ensure thorough distribution around the system.

3. Switch on the boiler, if fitted, and in safe working order. Allow the system water to reach 50°C, and then switch boiler off.

NOTE: Even boiler thermostat setting no.1 could exceed 50°C.

4. Circulate throughout the complete system for 15 minutes, reversing the flow direction regularly, and monitoring the system for leaks.
5. Close off all radiators (one valve only per radiator is enough), and allow the full flow to go through the coil in the cylinder (if present in the system).

6. Reverse the flow regularly.

7. Divert the full flow to the radiator circuit, in preparation to putting the full flow of the pump through each radiator in turn.

8. Fully open both valves of the nearest radiator, on the ground floor, to the flushing pump.

9. Flush this radiator, reversing the flow regularly, until all cold spots have disappeared, and the temperature across the radiator is consistent. Close the radiator valves.

Note: If your initial system check identified cold or partially blocked radiators, commence the individual radiator flushing procedure with the worst radiator first, progressing to less problematic radiators. This ensures that the strongest concentration of chemical is directed at the worst areas of the system.

10. Open the valves on the next radiator, and repeat the procedure.

11. Work through the rest of the radiators in turn, so that you have flushed every radiator individually, including upstairs radiators.

12. When you have flushed the last radiator, and obtained an even temperature across the surface, switch the pump into dumping mode, as previously described.

13. With only this radiator open, and the pump set to dump, run until the water leaving the dump hose is completely clear. Now operate the flow reverser and change the valves to dump in the opposite direction until clear. When dump water is clear, close radiator valve.

14. Go back to the previous radiator that you had flushed, ensure both valves are open, and repeat the dumping procedure on this one radiator, alternating the direction of flow in each direction as you dump. Close radiator valve.

15. Work your way back around the house in the opposite direction to previously, until you have carried out the dumping process on every radiator individually.

16. Now with the pump still set to dump direct the flow through the cylinder coil until it runs clear. Dump in the other direction until clear.

Note: You have used an acidic cleaner, and therefore a neutralising chemical should be circulated throughout the system to ensure that no traces of FX2 remain in the system.

Whilst FX2 contains specific inhibitors so that its presence during a power flush presents no problems, it is bad practice to leave system water acidic over a long period of time.

17. Return the pump into normal re-circulation mode, re-open all radiator valves, and the cylinder coil.

18. Slowly add 100 gm of NEUTRALISING CRYSTALS to the water in the pump tank whilst circulating throughout the system.





19. Circulate throughout the system for ten to fifteen minutes.

Continued on next page.

Kamco

**CF40 EVOLUTION & CF90 QUANTUM
OPERATING + SERVICING GUIDELINES**

20. Switch the pump into dumping mode.
21. After dumping for ten minutes (with coil and all radiators wide open), test the dump water with pH paper. Continue dumping until a pH reading of 7 is reached, or the same reading as the mains water supply in the property is achieved (both samples show the same colour).
- 
- Note: As an alternative an electronic pH meter may be used (see page F.12)
22. If you have a TDS meter (Total Dissolved Solids) it is useful to test the water at this stage. The reading should be compared with a mains water sample reading, and the dumping process continued until both readings are within 5-10% of each other.
23. Return to re-circulation mode and move to page B.10.



Kamco

CF40 EVOLUTION & CF90 QUANTUM OPERATING + SERVICING GUIDELINES

CHEMICAL FLUSHING PROCEDURE USING HYPER-FLUSH



1. Switch on the Clearflow pump.
2. Whilst re-circulating water through the pump and the heating system, slowly add 1 litre of HYPER-FLUSH to the Clearflow tank, sufficient for 10-12 radiator system, (unless it was added on a prior visit), and ensure thorough distribution around the system.
3. Switch on the boiler, if fitted, and in safe working order. Allow the system water to reach 50°C, and then switch boiler off.
NOTE: Even boiler thermostat setting no.1 could exceed 50°C.
4. Circulate throughout the complete system for half to one hour, reversing the flow direction regularly, and monitoring the system for leaks.
5. Close off all radiators (one valve only), and allow the full flow to go through the coil in the cylinder (if present in the system).
6. Reverse the flow regularly.
7. Divert the full flow to the radiator circuit, in preparation to putting the full flow of the pump through each radiator in turn.
8. Fully open both valves of the nearest radiator, on the ground floor, to the flushing pump.
9. Flush this radiator, reversing the flow regularly, until all cold spots have disappeared, and the temperature across the radiator is consistent. Close the radiator valves.

Note: If your initial system check identified cold or partially blocked radiators, commence the individual radiator flushing procedure with the worst radiator first, progressing to less problematic radiators. This ensures that the strongest concentration of chemical is directed at the worst areas of the system.
10. Open the valves on the next radiator, and repeat the procedure.
11. Work through the rest of the radiators in turn, so that you have flushed every radiator individually, including upstairs radiators.
12. When you have flushed the last radiator, and it has an even temperature across the surface, switch the pump into dumping mode, as previously.
13. With only this radiator open, and the pump set to dump, run until the water leaving the dump hose is completely clear. Now operate the flow reverser and change the valves to dump in the opposite direction until clear. When dump water is clear, close radiator valve.
14. Go back to the previous radiator that you had flushed, ensure both valves are open, and repeat the dumping procedure on this one radiator, alternating the direction of flow in each direction as you dump. Close radiator valve.
15. Work your way back around the house in the opposite direction to previously, until you have carried out the dumping process on every radiator individually.
16. Now with the pump still set to dump direct the flow through the cylinder coil until it runs clear. Dump in the other direction until clear.
17. If you have a TDS meter (Total Dissolved Solids) it is useful to test the water at this stage. The reading should be compared with a mains water sample reading, and the dumping process continued until both readings are within 5-10% of each other.
18. Return the flushing pump into normal re-circulation mode, re-open all radiator valves, and the cylinder coil, and move to page B.10.
19. **NOTE:** When using HYPER-FLUSH, there is no requirement to neutralise after the flushing process.

Kamco

CF40 EVOLUTION & CF90 QUANTUM OPERATING + SERVICING GUIDELINES

INHIBITION AND CORROSION PROTECTION



IMPORTANT

1. The system is now full of fresh, clean water, and in line with Building Regulations Part L : 2006, a good quality corrosion inhibitor, such as SYSTEMSAFE DM, must be added to the system water to prevent further corrosion and scaling.

To comply with Benchmark documentation, inhibitors must have passed the DWTA (Domestic Water Treatment Association) product performance standard and can be identified by this logo on the pack.



The inhibitor may be added to the system by using the Clearflow pump as follows:


2. Briefly open a dump valve to lower the water level in the tank to just above the minimum level, close the dump valve. Add the SYSTEMSAFE DM inhibitor into the tank. Allow circulation through the system for ten minutes, isolate the flushing pump from the heating system, and switch off.
3. If the system is vented, the residual water in the Clearflow tank, which will contain a small quantity of inhibitor, may be poured into a bucket and added to the F&E tank after this has been cleaned.

Note: In a pressurised system the inhibitor may be injected into the system using an IK6 injector, which will avoid wasting any inhibitor left in the tank. (see page F.4).

UPON COMPLETION

1. Restore system to normal, restoring radiator balance valves to original settings, removing any temporary isolating valves or caps on the expansion and cold feed pipes, and restoring non return valves to normal operation if necessary.
2. Before re-connecting the feed & expansion tank, it should be thoroughly cleaned, removing all traces of dirty water and sludge, and then disinfected with Kamchlor chlorine release tablets.

All Clearflow pumps are also very powerful descaling pumps, suitable for use when descaling combination boiler domestic water heat exchangers, any conventional domestic boiler, water heaters, direct fired water heaters, thermal store type water heaters, showers, and calorifiers.



Kamco

CF40 EVOLUTION & CF90 QUANTUM OPERATING + SERVICING GUIDELINES

SUMMARY OF CHEMICALS USED WHEN POWER FLUSHING

Product	Application	How much do you need?	How is it packed?
Power Flush FX2 liquid	Power flushing. For all systems except those containing aluminium. Pour into the tank whilst re-circulating.	2.5 litres (half of a blue pack) - up to 12 radiators.	Carton of 4 x 5 litre packs. (sufficient for 8 power flushes). Carton of 4 x 2.5 litre packs, with 4 one-shot tubes of Neutralising Crystals. (sufficient for 4 power flushes).
Neutralising Crystals	To neutralise the system water after dumping. Pour slowly into the Quantum tank whilst re-circulating clean water.	100 gm per 2.5 litres of FX2.	20 x 1 (100gm) shot tubes Carton of 6 x 2.5 kg pails. 15kg pail.
pH paper	To check that acidity has been removed. Dip 3cm in dump water and compare colour with chart.	Approx. 10 cm used per flush.	5 metre dispenser pack. (sufficient for at least 50 flushes).
Hyper Flush eXtra Powerful Non-acid flushing chemical	Power flushing systems containing aluminium or to pre treat heavily sludged systems. If possible, add to system 3 to 5 days before power flushing. May be added on the day.	1 litre for up to 12 radiators.	Carton of 12 x 1 litre packs. (sufficient for 12 houses). Carton of 4 x 5 litre packs 25 litre drum
Systemsafe DM corrosion & scale inhibitor, for all heating systems.	Protecting system. Add to system via the pump tank when power flushing is complete, or via injector, or into header tank.	1 litre for up to 12 radiators.	Carton of 12 x 1 litre packs. (sufficient for 12 houses). Carton of 4 x 5 litre packs 25 litre drum